


Date	Notes	By



Smart DC Lighting SDCS CIO
smartdclighting.com

Connect to SDCnet and PDnet Only!
Class 2, Class B Power Source
Max AmbientTemp 113F (45C)
Dry Locations Only; Not Plenum Rated

CSA C22.2 No. 141, Emergency Lighting Equipment
UL60730-1, CAN/CSA E60730-1
UL924, UL2108, CSA C22.2

Patent Pending, Made in the USA

Port Labels:
 CH 1: SDCnet (1), SENSOR (2-4)
 CH 2: PDnet
 CH 3: PDnet
 CH 4: PDnet
 EM TEST: SENSOR (5-8), SDCnet (5), RELAY3 (6), RELAY4 (7), USB/EM (8)

WIRE LEGEND	
	CAT 5-E (CLASS 2)

Revision Drawn By Date Level	A2	 13450 EM 529 RD HOUSTON, TX 77041	A
	DVR		
	06/30/25		
Approved	REL1	SDCS CIO TO SDCnet DEVICES	
	No scale		
Tols: .x = 0.25" .xx = 0.10"			